



Water Treatment Project

Sample Treatment Cost

Consider a prototype system with the following characteristics:

1. coagulant dosage of 60 mg/L
2. flowrate 800 mL/min
3. run time of 55 minutes
4. 2 in. of anthracite and 6 in. of filter sand
5. replace filter material once every five years
6. 3 prototype sedimentation tanks

Compute the total yearly cost of this system

1



Water Treatment Project

Coagulation and Flocculation Cost

The weight of coagulant (kg) required per gallon of treated water is estimated as:

$$wt_c \left[\frac{kg}{gal} \right] = \left(\frac{60 \text{ mg}}{L} \right) \left(\frac{3.785 \text{ L}}{\text{gallon}} \right) \left(\frac{kg}{10^6 \text{ mg}} \right)$$

$$= 2.2710 \times 10^{-4} \text{ kg/gal}$$

2



Water Treatment Project

Coagulation and Flocculation Cost

The number of coagulation and flocculation units NCF required are:

$$NCF = \left[\frac{20 \text{ (MGD)}}{5 \text{ (MGD)}} \right] \times 1.2$$

20% Factor of Safety

$NCF = 4.8$ or 5 units

3



Water Treatment Project

Coagulation and Flocculation Cost

The total yearly cost of the coagulation and flocculation system for 20 MGD is:

$$Cost_{CF} = 5 \left(\frac{\$25,000}{\text{year}} \right)$$

$$+ \left(2.2710 \times 10^{-4} \frac{kg}{gal} \right) \left(\frac{2 \times 10^7 \text{ gal}}{\text{day}} \right) \left(\frac{365 \text{ days}}{\text{year}} \right) \left(\frac{\$1}{kg} \right)$$

$$= \boxed{\$1,782,830}$$

4



Water Treatment Project

Sedimentation System Cost

Step 1 - Compute the prototype sediment tank **retention time** t_p

$$\text{Volume}_{\text{tank}} = 360 \text{ in.}^3 \left(\frac{\text{gallon}}{231 \text{ in.}^3} \right) = 1.56 \text{ gallons}$$

Two tanks are in operation

$$t_p = \frac{3(1.56 \text{ gallons})}{\left(800 \frac{\text{mL}}{\text{minute}} \right) \left(\frac{\text{L}}{1000 \text{ mL}} \right) \left(\frac{\text{gallon}}{3.785 \text{ L}} \right)} = 22.14 \text{ min}$$

5



Water Treatment Project

Sedimentation System Cost

Step 2 - The full-scale **treatment flowrate** Q_{ST} (gpm) per sedimentation tanks is:

$$Q_{ST} = \frac{75,000 \text{ gallons}}{22.14 \text{ min}} = 3,387 \text{ gpm}$$

6



Water Treatment Project

Sedimentation System Cost

Step 3 - The **effective flowrate** Q_{SE} (gpm) in a sedimentation tank is:

$$Q_{SE} = 3,387 \text{ gpm} \left(\frac{55 \text{ minutes}}{60 \text{ minutes}} \right) = 3,105 \text{ gpm}$$

7



Water Treatment Project

Sedimentation System Cost

Step 4 - The number of full-scaled sedimentation tanks, **NS** required to handle the daily volume is estimated as:

$$NS = \left[\frac{2 \times 10^7 \text{ (gpd)}}{3,105 \text{ (gpm)}} \right] \left[\frac{\text{day}}{1,440 \text{ min}} \right] \times 1.2$$

= 5.37 tanks or 6 tanks

8



Water Treatment Project

Sedimentation System Cost

The operation and maintenance costs per tanks is \$35,000/tanks

The yearly costs per sediment tank is:

$$\text{Cost}_s = 6 \text{ tanks} \left(\frac{\$35,000}{\text{tank}} \right) = \boxed{\$210,000}$$

9



Water Treatment Project

Filtration System Cost

Step 1 - Convert the average flowrate through the prototype filter (the 3.5 in. diameter prototype filter has an area of 0.0668 ft.²) into a prototype **filter loading rate** Q_F (gpm/ft.²).

$$Q_F = \left(\frac{800 \text{ mL}}{\text{minute}} \right) \left(\frac{\text{L}}{1000 \text{ mL}} \right) \left(\frac{\text{gallon}}{3.785 \text{ L}} \right) \left(\frac{1}{0.0668 \text{ ft.}^2} \right)$$

$$= 3.164 \text{ gpm / ft.}^2$$

10



Water Treatment Project

Filtration System Cost

Step 2 - The full-scale **treatment flowrate** (Q_T) is:

$$Q_{FT} = 3.164 \left(\frac{\text{gpm}}{\text{ft.}^2} \right) \times 1,000 \text{ ft.}^2 = 3,164 \text{ gpm}$$

11



Water Treatment Project

Filtration System Cost

Step 3 - Considering that each filter is inoperable during backwashing, the **effective flowrate** Q_E is:

$$Q_{FE} = 3,164 \text{ gpm} \left(\frac{55 \text{ minutes}}{60 \text{ minutes}} \right) = 2,900 \text{ gpm}$$

12



Water Treatment Project

Filtration System Cost

Step 4 - The number of full-scaled filters *NF* required to handle the daily volume is estimated as:

$$NF = \left[\frac{2 \times 10^7 \text{ (gpd)}}{2,900 \text{ (gpm)}} \right] \left[\frac{\text{day}}{1,440 \text{ min}} \right] \times 1.2$$

= 5.75 filters or 6 filters

13



Water Treatment Project

Filtration System Cost

The yearly cost per filter is:

$$Cost_F = 6 \text{ filters} \left(\frac{\$45,000}{\text{filter}} \right) = \$270,000$$

14



Water Treatment Project

Filtration System Cost

The yearly cost for anthracite is:

$$Cost_{FMA} = 2 \text{ (in.)} \left(\frac{\$9.50}{\text{ft.}^3} \right) \left(\frac{\text{ft}}{12 \text{ in.}} \right) (1,000 \text{ ft.}^2) \left(\frac{NF}{5} \right)$$

The yearly cost for filter sand is:

$$Cost_{FMS} = 6 \text{ (in.)} \left(\frac{\$5.90}{\text{ft.}^3} \right) \left(\frac{\text{ft}}{12 \text{ in.}} \right) (1,000 \text{ ft.}^2) \left(\frac{NF}{5} \right)$$

$$Cost_{FM} = \$1,900 + \$3,540 = \$5,440$$

15



Water Treatment Project

Total Treatment System Cost

Total Cost = \$1,782,830 Coagulation

+ \$210,000 Sedimentation

+ \$270,000 Filtration

+ \$5,440 Filtration Media

16



Water Treatment Project

Total Treatment System Cost

Total Cost = \$2,268,270

17



Water Treatment Project

Any questions?



18